

**CONSTRUCTION CHANGE DIRECTIVE**

PROJECT: IRC-1829 Central Regional WWTF Roof Replacement NO.: 01  
OWNER: Indian River County DATE OF ISSUANCE: 03-29-2023  
ENGINEER: REI Engineers  
CONTRACTOR: Atlantic Roofing II of Vero Beach Inc. REI PROJECT NO: 019TPA-018

THIS DIRECTIVE AUTHORIZES THE CONTRACTOR TO PROCEED WITH THE WORK DESCRIBED BELOW IN ADVANCE OF AN EXECUTED CHANGE ORDER.

Please submit an itemized proposal for changes in the Contract Sum and Contract Time for proposed modifications to the Contract Documents described herein. Submit proposal within three (3) days or notify the Engineer in writing of the date on which you anticipate submitting your proposal.

Description:

Contractor to provide a proposal for the following out of scope work items.

1. Building "B": Add exterior wall stucco repairs and exterior wall painting of the first and second story building sections performed in conjunction with roof replacement to protect the installed roof system from water intrusion of the adjacent vertical walls.
2. Building "B": Extend vertical wall flashing to encapsulate damaged wall stucco on the lower east and west elevation walls of roof section "B3" performed in conjunction with roof replacement to protect the installed roof system from water intrusion of the adjacent vertical walls.
3. Building "C": Extend roof flashing system to incorporate the adjacent holding tank maintenance service catwalk.

DIRECTIVE REQUESTED BY:

REI Engineers  
Engineer

Owner

*Mark Renninger*  
By: Mark Renninger, Sr Project Engineer Date

By: \_\_\_\_\_ Date

Attachments:

Copies:  Owner  Engineer  Contractor

This item has been digitally signed and sealed by Mark Renninger on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic .copies  
'00'04- 13:57:47 2023.04.03

